

NTN 023

Changing Intumescent Systems within a Single Project

Nullifire
Smart Protection

Statement

During construction phase on a project, different intumescent systems are sometimes applied either from the same or differing manufacturers.

When different systems are applied to separate elements of structure this would not cause concern in terms of fire protection to the structure as a whole. Each specific section would fall under the approvals of the specific coating system used.

Where adjacent sections coated in different intumescent meet, every attempt should be made to keep over spray to a bare minimum.

Under no circumstances should products be mixed on any given structural steel section.

All intumescent coatings should be applied in accordance with the latest technical data sheets to ensure the specification would be met.

Technical Service

Nullifire has a team of experienced Technical Sales Representatives who provide assistance in the selection and specification of products. For more detailed information, service and advice, please call Technical Services on 01942 251 400.