Warringtonfire
Chiltern House
Stocking Lane
High Wycombe
HP14 4ND
United Kingdom
T: +44 (0)1494 569750
W: www.warringtonfire.com

Title:

The fire resistance performance of seven pipe penetrations sealing systems and two electrical penetration systems within a horizontal supporting construction, when tested in accordance with BS EN 1363-1: 2012 and BS EN 1366-3: 2009

WF Report No:

422179

Prepared for:

Tremco-Illbruck Ltd

Coupland Road
Hindley Green
Wigan
WN2 4HT

Date:

19th December 2019

Notified Body No:

1314

1762

Registered Office: Warringtonfire Testing and Certification Limited, 10 Lower Grosvenor Place, London, United Kingdom, SW1W 0EN. Reg No. 11371436

Wilt u het volledige rapport ontvangen?
Nullifire Smart Protection
KLIK HIER

UL INTERNATIONAL (UK) LTD
Wonersh House, Building C,
The Guildway,
Old Portsmouth Road,
Guildford. GU3 1LR.
United Kingdom.

Designated according to Article 29 of Regulation (EU) No 305/2011

Member of EOTA
www.eota.eu

designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, www.eota.eu)

European Technical Assessment

ETA 17/0391
of 23/10/2017

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011:	**UL International (UK) Ltd**
Trade name of the construction product	Nullifire FP302 / Nullifire FP160
Product family to which the construction product belongs	Fire Stopping and Sealing Product: • Penetration Seals
Manufacturer	tremco-illbruck Ltd Coupland Rd Hindley Green Wigan WN2 4HT
Manufacturing plant(s)	A/018
This European Technical Assessment contains	30 pages including 1 Annex which forms an integral part of this assessment.
This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of	ETAG 026-2, edition 2011, used as European Assessment Document (EAD).

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

Wilt u het volledige rapport ontvangen? Nullifire Smart Protection KLIK HIER

ETA-Danmark A/S
Göteborg Plads 1
DK-2150 Nordhavn
Tel. +45 72 24 59 00
Internet
www.etadanmark.dk

Authorised and notified according to Article 29 of the Regulation (EU)
No 305/2011 of the European Parliament and of the Council of 9 March 2011

MEMBER OF EOTA

European Technical Assessment ETA-20/1318 of 2021/01/01

I General Part

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: ETA-Danmark A/S

Trade name of the construction product:	Nullifire FP302 / Nullifire FP160
Product family to which the above construction product belongs:	Fire Stopping and Sealing Product: • Penetration Seals
Manufacturer:	Tremco CPG UK Limited Torrington Avenue Coventry CV4 9TJ United Kingdom
Manufacturing plant:	A/018
This European Technical Assessment contains:	29 pages including 1 annexes which form an integral part of the document
This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, on the basis of:	EAD 350454-00-1104 for Fire stopping and fire sealing products - Penetration seals, September 2017
This version replaces:	-

Wilt u het volledige rapport ontvangen?
Nullifire Smart Protection
KLIK HIER